



# LICENCE

No. 15694 replaces No.12135

Issued to:

Applicant:

**General Cable CELCAT**  
**Energia e Telecomunicações S.A.**  
**Av. Marquês de Pombal, 36/38**  
**Morelena**  
**2715-055 PERO PINHEIRO**  
**Portugal**

Licensee:

**General Cable CELCAT**  
**Energia e Telecomunicações S.A.**  
**Av. Marquês de Pombal, 36/38**  
**Morelena**  
**2715-055 PERO PINHEIRO**  
**Portugal**

Product : cables for fixed wiring

Trade name(s) : GENERAL CABLE 7

Type(s)/model(s) : EAXVB, EXVB

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location according to CCA Group Operational Document CIG 021
- a certification agreement with the number 1077

SGS CEBEC hereby grants the right to use the CEBEC certification mark



The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 08/05/2008

  
ir. R. Maquestiau,  
Managing Director

© Only integral publication of this certificate, including the annex, is allowed

**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product : cables for fixed wiring  
Trade name(s) : GENERAL CABLE 7  
Type(s)/Model(s) : EAXVB, EXVB  
description : XLPE insulated cables - unarmoured  
rated voltage U<sub>0</sub>/U : 0.6/1 kV

**Product data - type EXVB**

number of conductors : 1-5  
cross-sectional area(s) : 1.5-500 mm<sup>2</sup>  
additional information : copper conductor

**Product data - type EAXVB**

number of conductors : 4  
cross-sectional area(s) : 16-240 mm<sup>2</sup>  
additional information : aluminium conductor

**TESTS****Test requirements**

NBN HD 603:2007/Partie 5 - Section 5-A

**Test results**

The test results are laid down in certification file ref.581504/01

**Remarks**

This certificate is based on test reports ref. 570615/01, 570933/01.



**Conclusion**

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi

*[Handwritten signature]* 2008/05/08 *[initials]*

Department Manager,  
Product Certification :

*[Handwritten signature]*

Certification Manager :

*[Handwritten signature]* 2008/05/26

0 1 2 3 4 5



**FACTORY LOCATION(S)**

General Cable CELCAT  
Energia e Telecomunicações S.A.  
av. Marquês de Pombal  
36-38 Morelena  
2715-055 PERO PINHEIRO  
Portugal

0 1 2 3 4 5

